

ANALYTICAL DATA AND APPROXIMATE DISTRIBUTION FOR CAPE TOWN DRINKING WATER

Sample period: 1 July 2015 to 30 June 2016

The City of Cape Town has been awarded a 2012 Blue Drop Certificate for the quality of its drinking water by the Department: Water & Sanitation (DWS). This assures Cape Town’s residents that their tap water is safe to drink and complies with stringent quality checks. The City of Cape Town obtained the highest score of 98,14% in the Western Cape and is one of ten municipalities in the Western Cape that achieved Blue Drop status. The City of Cape Town also received a Platinum Blue Drop Award for its consistent excellent performance for four years and remains in the top performing group of water service authorities in South Africa.

To qualify for a Blue Drop Certificate a water service authority must score at least 95% in meeting the criteria set by the DWS. These include the maintenance and monitoring of the catchment and storage areas and facilities, the pipeline and distribution systems and the water treatment facilities and processes. The water quality has to meet the standard from where it is stored until it is used by the consumer. Adequate staffing with suitable skills coupled to a training regime also forms part of the certification process which is done annually by virtue of a physical audit conducted by DWS officials.

Below are the results for the water quality provided across the City of Cape Town for the indicated period as well as the distribution areas normally linked to the water treatment plants supplying the City. The annual publication of the water quality results is also a requirement of the Blue Drop certification process.

PARAMETERS	SANS 241: 2015 Specs	BLACKHEATH SUPPLY Typical analysis (max 430 Mℓ/day)	FAURE SUPPLY Typical analysis (max 500 Mℓ/day)	KLOOF NEK SUPPLY Typical analysis (max 22.5 Mℓ/day)	STEENBRAS SUPPLY Typical analysis (max 150 Mℓ/day)	VOËLVLEI SUPPLY Typical analysis (max 273 Mℓ/day)	WEMMERSHOEK SUPPLY Typical analysis (max 250 Mℓ/day)	BROOKLANDS SUPPLY Typical analysis (max 5.5 Mℓ/day)	HELDERBERG SUPPLY Typical analysis (max 12 Mℓ/day)	WITZANDS SUPPLY Typical analysis max 15 Mℓ/day	CONSTANTIA NEK SUPPLY Typical analysis max 3 Mℓ/day
PHYSICAL & AESTHETIC DETERMINANDS											
Colour mg/ℓ Pt-Co	≤5	5	5	6	5	5	5	6	5	5	5
Conductivity mS/m	≤170	12	15	20	15	18	10	54	17	25	20
Total Dissolved Solids mg/ℓ	≤1200	82	98	134	99	118	64	362	117	168	137
Turbidity NTU	Operational ≤1 Aesthetic ≤5	0.70	0.62	0.82	0.67	0.93	0.80	0.61	0.86	0.66	0.88
pH (pH units)	≥5.0 to ≤9.7	8.3	8.4	8.5	8.3	8.2	8.1	8.4	8	7.8	8.2
CHEMICAL - MACRO DETERMINANDS											
Free Chlorine as Cl ₂ mg/ℓ	≤5	0.7	0.9	0.8	0.7	0.6	1.0	1.0	0.7	0.6	0.9
Nitrate as N mg/ℓ	≤11.0	0	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
Nitrite as N mg/ℓ	≤0.9	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
Combined nitrate plus nitrite	≤1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
Sulphate as SO ₄ ²⁻ mg/ℓ	Aesthetic ≤250 Acute health ≤500	13	24	34	17	22	8	114	15	23	33
Fluoride as F ⁻ mg/ℓ	≤1.5	0.1	0.1	0.1	0.1	0.1	0.1	<0.1	0.1	0.1	0.1
Ammonia as N mg/ℓ	≤1.5	<0.4	<0.4	<0.4	<0.4	<0.4	<0.4	<0.4	<0.4	<0.4	<0.4
Chloride as Cl ⁻ mg/ℓ	≤300	16	18	21	23	25	12	70	29	34	27
Sodium as Na mg/ℓ	≤200	7	8	13	12	12	5	34	14	17	16
Zinc as Zn mg/ℓ	≤5	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
CHEMICAL - MICRO DETERMINANDS											
Antimony as Sb µg/ℓ	≤20	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Arsenic as As µg/ℓ	≤10	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Barium as Ba µg/ℓ	≤700	50	50	50	51	50	50	50	50	50	50
Boron as B mg/ ℓ	≤2.4	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
Cadmium as Cd µg/ℓ	≤3	<3	<3	<3	<3	<3	<3	<3	<3	<3	<3
Chromium (total) as Cr µg/ℓ	≤50	<5	<5	<5	<5	<5	<5	<5	<5	<5	<5
Copper as Cu µg/ℓ	≤2000	<10	12	16	12	12	11	11	15	14	11
Cyanide as CN ⁻ µg/ℓ	≤200	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10
Iron as Fe µg/ℓ	Chronic Health ≤400 Aesthetic ≤300	80	88	70	58	69	98	<50	72	60	55
Lead as Pb µg/ℓ	≤10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10
Manganese as Mn µg/ℓ	Chronic Health ≤400 Aesthetic ≤100	19	6	11	8	6	15	8	9	7	13
Mercury as Hg µg/ℓ	≤6	<5	<5	<5	<5	<5	<5	<5	<5	<5	<5
Nickel as Ni µg/ℓ	≤70	<5	<5	<5	<5	<5	<5	<5	<5	<5	<5
Selenium as Se µg/ℓ	≤40	<1	<1	<1	<1	<1	<1	4	<1	<1	<1
Uranium as U ug/ℓ	≤30	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10
Aluminium as Al µg/ℓ	≤300	78	67	166	130	52	110	78	116	52	231
CHEMICAL - ORGANIC DETERMINANDS											
Total organic Carbon mg/ℓ	≤10	2	2	2	2	2	2	3	2	2	2
Trihalomethanes											
Chloroform µg/ℓ	≤300	9	9	24	2	34	34	10	73	52	48
Bromoform µg/ℓ	≤100	3	1	0	1	1	1	3	3	3	0
Dibromochloromethane µg/ℓ	≤100	5	2	2	2	2	2	7	7	8	3
Bromodichloromethane µg/ℓ	≤60	7	2	1	0	3	1	9	17	15	9
Combined Trihalomethane	≤1	0.2	0.1	0.1	0.0	0.2	0.0	0.3	0.6	0.5	0.3
Phenols µg/ℓ	≤10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10
MICROBIOLOGICAL DETERMINANDS											
E coli count/100 mℓ	Not detected	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Heterotrophic Plate Count count/mℓ	≤1000	14	2	51	9	20	7	2	10	3	2
Total coliforms count/100mℓ	≤10	4	1	5	1	1	1	2	1	5	1
Protozoan parasites											
Cryptosporidium species count/10ℓ	Not detected	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Giardia species count/10ℓ	Not detected	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
OTHER											
Hardness (total) as CaCO ₃ mg/ℓ	-	34	43	52	30	44	28	138	38	66	47
Alkalinity as CaCO ₃ mg/ℓ	-	19	19	26	14	20	19	11	19	41.6	19.1
Calcium as Ca mg/ℓ	-	11.1	14.2	18.5	9.5	13.9	9.6	47.3	12.0	21.6	16.0
Potassium as K mg/ℓ	-	0.6	0.7	0.4	1.3	0.8	0.4	1.3	0.9	1.17	0.46
Magnesium as Mg mg/ℓ	-	1.43	1.47	1.45	1.47	2.39	0.94	4.86	2.08	2.84	1.79

APPROXIMATE AREAS OF WATER DISTRIBUTION (variable due to optimising of raw water resources, seasonal variations, water treatment plant/reservoir serviceability, systems operations, and parameters also variable due to mixing in distribution system)

BLACKHEATH:	Cape Flats, Mitchells Plain, Muizenberg, Fish Hoek, Southern Suburbs and Southern Suburbs (high lying areas on mountainside and Constantia Valley), City Bowl, Bellville, Kuils River, Blue Downs, Eerste River, Khayelitsha, Durbanville, Elsies River, Somerset West, Strand, Nyanga/Gugulethu
BROOKLANDS:	Simon’s Town
CONSTANTIANEK:	Hout Bay (water blended with supplies from Steenbras and/or Blackheath)
FAURE:	Cape Flats, Mitchells Plain, Muizenberg, Fish Hoek, Southern Suburbs, Khayelitsha, Somerset West, Strand, Philippi
HELDERBERG:	Somerset West
KLOOFNEK:	Camps Bay, Sea Point, Tamboerskloof/Gardens (high lying areas)
STEENBRAS:	Southern Suburbs (high lying areas on mountainside and Constantia Valley), Somerset West/Gordon’s Bay (high lying areas) Fish Hoek and the Far South Peninsula
VOËLVLEI:	Northern Suburbs (Atlantis to Milnerton), Epping, City Bowl, Green Point, Durbanville/Kraaifontein (upper areas)
WEMMERSHOEK:	Paarl to Bellville, Northern Suburbs, City Bowl, Durbanville, Kraaifontein
WITZANDS:	Atlantis (water blended with supplies from Voëlvlei)

ACHMAT EBRAHIM
CITY MANAGER
193/2016

